

ELISE ROTHSCHILD

## DEPARTMENT OF ENVIRONMENTAL HEALTH LAND AND WATER QUALITY DIVISION

P.O. BOX 129261, SAN DIEGO, CA 92112-9261 Phone: (858) 565-5173 Fax: (858) 694-3670 www.sdcdeh.org AMY HARBERT ASSISTANT DIRECTOR

DATE: January 9, 2019

TO: Bronwyn Brown, Project Manager

Planning & Development Services

FROM: Scott Rosecrans, Environmental Health Specialist III

Land & Water Quality Division

Department of Environmental Health (DEH)

PDS2018-GPA-18-010/REZ-18-007/MUP-18-022, JVR Energy Park

APN: 20 various APN's

## **SCOPING DISCUSSION:**

DEH has reviewed the proposed General Plan Amendment/Rezone/Major Use Permit, dated 11/16/18, for the proposed new solar power generation and storage facility.

## **RECOMMENDATION:**

The Department of Environmental Health, Land & Water Quality Division, has no objection to the approval of the project. The following conditions of approval should be applied:

- Any water wells located on the property that are not to be used as a water supply wells must be destroyed under permit and inspection by DEH.
- The applicant must obtain all necessary permits from the County of San Diego-Department of Environmental Health-Hazardous Materials Division for the reportable quantities of hazardous materials (batteries) on the site.
- All onsite wastewater treatment systems proposed to be abandoned, must be pumped, collapsed, and backfilled, prior to grading permit/building permit issuance. This applies to septic tanks and seepage pits that are not rockfilled.

If you have any questions regarding the above, please call me at (619)208-0337.

Sincerely,

Scott Rosecrans EHS III, REHS